



# THE CITY OF NASHUA

*Wastewater Treatment Facility  
Department of Public Works*

*"The Gate City"*

January 11, 2019

Joy Hilton  
U.S. Environmental Protection Agency  
Region 1 - New England  
5 Post Office Square, Suite 100  
Mail Code: OES04-3  
Boston, MA 02109-3912

Dear Ms. Hilton,

This letter is a summary of our Annual 2018 DMR submission for CSO reporting.

During the year of 2018 the Nashua Wastewater Treatment Facility did see some Combined Sewer Overflow occurrences. This year we had adequate discharges at CSO's 003, 004, 005, 006, 008, 009 and 014; however the staff was only able to sample CSO 005 East Hollis St. and CSO 014 Bancroft St. on August 14, 2018 and obtain samples for E.coli analysis. All other occurrences were unable to be sampled because either, the duration was too short and a crew was unable get to the location within the first 30 minutes of discharge, or environmental conditions (severe weather and/or poor visibility) made access to the location dangerous or impossible.

The samples obtained from CSO 005 and CSO 014 on August 14, 2018 both had an E. coli result of >2419.6 mpn/100 ml resulting in violations of the permit limit of 1000 mpn/100 ml.

For complete data please refer to submitted reports and please contact the facility with any questions.

Regards,

David L Boucher, Superintendent  
Nashua Wastewater Treatment Facility

Cc: Lisa Fauteux, Director of Public Works